



818 Commercial Street, Room 203, Astoria, Oregon 97103, Phone: (503) 325-0435, Fax: (503) 325-0459

Email: crest@columbiaestuary.org, Website: www.columbiaestuary.org

February 14, 2024

ADDENDUM #2 WOLF BAY RESTORATION PROJECT – CONSTRUCTION RFP

Dear RFP Holder:

The following addenda apply to the Wolf Bay Restoration Project - Construction RFP. This information is in addition to Addendum #1 which was issued on February 8, 2024.

Project proposals are still due via email by 4pm on February 16, 2024.

Addendum #2 Contains clarifications and additional information on the following:

1. Geotechnical Clarifications UPDATE

Hanson to verify what the ultimate and allowable load should be assuming the factor of safety is 2.5.

UPDATE Hanson (Structural Engineer) Response:

Updated sheets with the correction to the ultimate pile load have been provided. The ultimate load language within the plan set remains the same, it is only the numerical value that was updated to match the design.

The factor of safety used in the design is 2.5. This is for the axial load on the piles.

Ultimate load = 663 kips

Allowable (service) load = 265 kips

As before, please email all proposal/bid documents in PDF form to Jason Smith (jsmith@columbiaestuary.org) no later than 4pm on February 16, 2024.

Regards,

Jason R. Smith
CREST Habitat Restoration Project Manager
Ph: (503) 325-0435 x 219